

TYPE APPROVAL CERTIFICATE

DNV·GL

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No. **14 218 - 15 HH**

Company **Delta Electronics (Thailand) Public Co., Ltd.
909 Soi 9, Moo 4, Bangpoo Industrial Estate (E.P.Z.)
Pattana 1 Rd, Tambol Phraksa, Amphur Muang
Samutprakarn 10280, THAILAND**

Product Description **DIN-Rail Power Supply**

Type **DRM-24V120W1PN(y)**

Environmental Category **C, EMC2**

Technical Data / **Model code: DRM-24V120W1PN(y)**

Range of Application

• (y): any capital letter A~Z (excluding I, L, O, Q) or any digit 2~9 or blank

Input Rating:

• AC 100-240 V, 50-60 Hz, 1.4 A

• DC 110-300 V, 1.25 A

Output Rating:

• Voltage: 24 V DC, 5 A (adjustable 24...28 V DC)

• Max. output power: 120 W (power derating to be observed)

Horizontal mounting: power derating of 3W/°C for ambient temp. Above 50°C

Vertical mounting: power derating of 3W/°C for ambient temp. Above 60°C

LED Signals / Output contact:

• Green LED DC OK

• Red LED Oveload

• Output Realy Contact: DC OK,

(max. contact rating: 30V / 1 A, resistive load)

Mounting:

• DIN-Rail

Degree of protection: IP 20

Test Standard **Guidelines for the Performance of Type Approvals, Chapter 2- Test Requirements for Electrical / Electronic Equipment and Systems (VI-7-2), Edition 2012**

Documents **Test Reports: SIQ No. T211-0117/15, SIQ No. T251-0224/15
Test Report: SIQ T223-0066/15 (acc. To IEC 60950-1)
Construction Drawings; Circuit Diagrams; Installation Notes
Initial Assessment Report (90.02a) of 2015-05-11**

Remarks **Product approved by this certificate is accepted for installation on all vessels classed by DNV GL.**

Valid until **2020-07-08**

Page **1 of 1**

File No. **I.M.03**

Hamburg, 2015-08-07

Type Approval Symbol




Arne Schaarmann


Dariusz Lesniewski

DNV GL